


## Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Limit Level - 70.0 dB(A) / School Exam - 65.0 dB(A)

Location M-N3 - S.K.H. Tsoi Kung Po Secondary School							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
02-Dec-24	17:06	Sunny	67.0	71.1	53.6	67.7	67 Measured $\leq$ Baseline
12-Dec-24	11:15	Sunny	66.2	69.4	54.5	67.7	66.2 Measured $\leq$ Baseline
18-Dec-24	9:29	Sunny	67.0	70.3	57.8	67.7	67 Measured $\leq$ Baseline
24-Dec-24	15:00	Sunny	66.7	67.6	58.5	67.7	66.7 Measured $\leq$ Baseline
30-Dec-24	16:12	Sunny	65.7	68.8	56.3	67.7	66 Measured $\leq$ Baseline

## Noise Levels



Title Contract No. HY/2019/13 Central Kowloon Route – Buildings, Electrical and Mechanical Works  Graphical Presentation of Construction Noise Monitoring Results	Scale	N.T.S	Project	No. MA20024	CINOTECH
	Date	Dec-24	Appendix	G	