

Appendix H – Summary of Exceedance

Exceedance Record for Contract No. HY/2019/13

Reporting Month: December 2025

(A) Exceedance Record for Air Quality:

(NIL in the reporting month)

(B) Exceedance Record for Construction Noise:

One(1) Action Level is recorded in the reporting month, as a complaint was received via the Water Supplies Department on 10 December 2025 regarding a noise nuisance from breaking works at the Ho Man Tin site that impacts the nearby residents. The Contractor has taken the necessary mitigation measures to minimise the noise nuisance by installing additional noise barriers on the hoarding and the breaker tip of the excavator, ensuring only one breaker is operating at a time, and operating the breaker intermittently. The monitoring results in the nearest station have been reviewed. No Limit Level exceedance of the construction noise was recorded after implementing the mitigation measures. The Complaint Investigation was completed, and the report was finalised on 19 Dec 2025. The complainant and EPD have no further comment.

(C) Exceedance Record for Landscape and Visual:

(NIL in the reporting month)