


## Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Limit Level - 70.0 dB(A) / School Exam - 65.0 dB(A)

Location M-N3 - S.K.H. Tsoi Kung Po Secondary School							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
03-Feb-25	15:51	Fine	65.0	68.0	54.3	67.7	65 Measured $\leq$ Baseline
14-Feb-25	9:00	Fine	66.9	70.2	62.7	67.7	66.9 Measured $\leq$ Baseline
20-Feb-25	15:41	Cloudy	67.0	69.4	58.2	67.7	67 Measured $\leq$ Baseline
26-Feb-25	16:42	Cloudy	66.6	68.9	56.1	67.7	66.6 Measured $\leq$ Baseline

## Noise Levels



Title Contract No. HY/2019/13 Central Kowloon Route – Buildings, Electrical and Mechanical Works  Graphical Presentation of Construction Noise Monitoring Results	Scale N.T.S	Project No. MA20024	
	Date Feb-25	Appendix G	