


Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Location M-N3 - S.K.H. Tsoi Kung Po Secondary School							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
03-Jan-24	11:21	Fine	66.2	68.5	58.1	67.7	66 Measured ≤ Baseline
09-Jan-24	15:00	Sunny	67.1	70.3	61.9	67.7	67 Measured ≤ Baseline
15-Jan-24	12:58	Sunny	67.1	69.5	62.7	67.7	67 Measured ≤ Baseline
25-Jan-24	13:55	Fine	66.8	69.3	60.9	67.7	67 Measured ≤ Baseline
31-Jan-24	12:56	Cloudy	67.3	70.2	61.2	67.7	67 Measured ≤ Baseline

Noise Levels



Title Contract No. HY/2019/13 Central Kowloon Route – Buildings, Electrical and Mechanical Works Graphical Presentation of Construction Noise Monitoring Results	Scale N.T.S	Project No. MA20024	
	Date Jan-24	Appendix G	