


Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

Limit Level - 70.0 dB(A) / School Exam - 65.0 dB(A)

| Location M-N3 - S.K.H. Tsoi Kung Po Secondary School | | | | | | | |
|--|-------|---------|-----------------------|-----------------|-----------------|-----------------|-------------------------------|
| Date | Time | Weather | Unit: dB (A) (30-min) | | | | |
| | | | Measured Noise Level | | | Baseline Level | Construction Noise Level |
| | | | L _{eq} | L ₁₀ | L ₉₀ | L _{eq} | L _{eq} |
| 02-Jul-24 | 14:53 | Fine | 68.1 | 70.6 | 63.0 | 67.7 | 57.5 |
| 08-Jul-24 | 15:00 | Sunny | 70.3 | 72.1 | 66.0 | 67.7 | 66.8 |
| 18-Jul-24 | 16:06 | Sunny | 68.2 | 70.9 | 62.0 | 67.7 | 58.6 |
| 24-Jul-24 | 15:26 | Fine | 67.7 | 69.5 | 61.5 | 67.7 | 67.7 Measured \leq Baseline |
| 30-Jul-24 | 16:00 | Fine | 62.4 | 64.8 | 56.4 | 67.7 | 62 Measured \leq Baseline |

Noise Levels



| | | | | | |
|--|-------|--------|----------|-------------|----------|
| Title Contract No. HY/2019/13 Central Kowloon Route – Buildings, Electrical and Mechanical Works Graphical Presentation of Construction Noise Monitoring Results | Scale | N.T.S | Project | No. MA20024 | CINOTECH |
| | Date | Jul-24 | Appendix | G | |