


Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)  
Limit Level - 70.0 dB(A) / School Exam - 65.0 dB(A)

Location M-N3 - S.K.H. Tsoi Kung Po Secondary School							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
03-Nov-25	16:06	Cloudy	66.1	68.3	57.4	67.7	66.1 Measured ≤ Baseline
13-Nov-25	15:20	Fine	67.5	71.2	60.8	67.7	67.5 Measured ≤ Baseline
19-Nov-25	15:55	Fine	68.3	71.5	62.4	67.7	59.4
25-Nov-25	15:00	Fine	64.3	65.6	60.8	67.7	64.3 Measured ≤ Baseline

## Noise Levels



<b>Title</b> Contract No. HY/2019/13 Central Kowloon Route – Buildings, Electrical and Mechanical Works  Graphical Presentation of Construction Noise Monitoring Results	<b>Scale</b> N.T.S	<b>Project</b> No. MA20024	<b>CINOTECH</b>
	<b>Date</b> Nov-25	<b>Appendix</b> G	