


Appendix G - Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)  
Limit Level - 70.0 dB(A) / School Exam - 65.0 dB(A)

Location M-N3 - S.K.H. Tsoi Kung Po Secondary School							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L <sub>eq</sub>	L <sub>10</sub>	L <sub>90</sub>	L <sub>eq</sub>	L <sub>eq</sub>
06-Oct-25	11:00	Sunny	65.5	68.9	54.9	67.7	65.5 Measured ≤ Baseline
16-Oct-25	16:51	Sunny	66.7	69.0	59.2	67.7	66.7 Measured ≤ Baseline
22-Oct-25	16:57	Cloudy	66.8	69.8	58.1	67.7	66.8 Measured ≤ Baseline
28-Oct-25	16:50	Sunny	62.9	65.8	55.6	67.7	62.9 Measured ≤ Baseline

Noise Levels



Title	Contract No. HY/2019/13 Central Kowloon Route – Buildings, Electrical and Mechanical Works	Scale	Project	CINOTECH
	Graphical Presentation of Construction Noise Monitoring Results	N.T.S	No. MA20024	
		Date	Appendix	
		Oct-25	G	